



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611121

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: St. Reg

Fred Hauck  
20104 NYS Route 3  
Watertown, NY 13601

Project / PO Number: N/A  
Received: 09/21/2016 14:00  
Reported: 10/29/2016 16:14

Analytical Testing Parameters

Client Sample ID: 6  
Lab Sample ID: J611121-01  
Sample Type: Grab

Collected By: RF/FH  
Collection Date: 09/20/16  
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1634

Analytical Testing Parameters

Client Sample ID: 8B  
Lab Sample ID: J611121-02  
Sample Type: Grab

Collected By: RF/FH  
Collection Date: 09/20/16  
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1634

Analytical Testing Parameters

Client Sample ID: 8A  
Lab Sample ID: J611121-03  
Sample Type: Grab

Collected By: RF/FH  
Collection Date: 09/20/16  
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0010	0.015	0.0010	mg/L		10/05/16 0800	10/12/16 1635



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J61121-04
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1636

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J61121-05
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1638

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J61121-06
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1640



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 45B
Lab Sample ID: J61121-08
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1640

Analytical Testing Parameters

Client Sample ID: 71
Lab Sample ID: J61121-09
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1641

Analytical Testing Parameters

Client Sample ID: 45A
Lab Sample ID: J61121-10
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1642



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 62
Lab Sample ID: J61121-11
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1642

Analytical Testing Parameters

Client Sample ID: 58
Lab Sample ID: J61121-12
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1643

Analytical Testing Parameters

Client Sample ID: 46A
Lab Sample ID: J61121-13
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1644



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J61121-14
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1646

Analytical Testing Parameters

Client Sample ID: 57
Lab Sample ID: J61121-15
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0011, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1646

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J61121-16
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0013, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1648



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 64
Lab Sample ID: J61121-17
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1649

Analytical Testing Parameters

Client Sample ID: 65
Lab Sample ID: J61121-18
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1649

Analytical Testing Parameters

Client Sample ID: 63
Lab Sample ID: J61121-19
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/05/16 0800, 10/12/16 1650



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 61
Lab Sample ID: J61121-20
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0942

Analytical Testing Parameters

Client Sample ID: 3B
Lab Sample ID: J61121-21
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0942

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J61121-22
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0944



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 59
Lab Sample ID: J61121-23
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0945

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J61121-24
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0946

Analytical Testing Parameters

Client Sample ID: 54
Lab Sample ID: J61121-25
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0946





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 55
Lab Sample ID: J61121-26
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0948

Analytical Testing Parameters

Client Sample ID: 60
Lab Sample ID: J61121-27
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0019, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0949

Analytical Testing Parameters

Client Sample ID: 44
Lab Sample ID: J61121-28
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0950



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 43
Lab Sample ID: J61121-29
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0950.

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J61121-30
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0952.

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J61121-31
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0012, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0953.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 19
Lab Sample ID: J61121-32
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0953

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J61121-33
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0954

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J61121-34
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0955



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J61121-35
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0955

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J61121-36
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0957

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J61121-37
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 0958



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J61121-38
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1000

Analytical Testing Parameters

Client Sample ID: 26
Lab Sample ID: J61121-39
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1001

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J61121-40
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1001



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J61121-41
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1002

Analytical Testing Parameters

Client Sample ID: 20
Lab Sample ID: J61121-42
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1003

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J61121-43
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1003



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 22
Lab Sample ID: J61121-44
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1004

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J61121-45
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1005

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J61121-46
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1008



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J61121-47
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1009

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J61121-48
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1009

Analytical Testing Parameters

Client Sample ID: 28B
Lab Sample ID: J61121-49
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1010





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J61121-50
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1011

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J61121-51
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1011

Analytical Testing Parameters

Client Sample ID: 28A
Lab Sample ID: J61121-52
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1012



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 49
Lab Sample ID: J61121-53
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1013

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J61121-54
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1013

Analytical Testing Parameters

Client Sample ID: 37-1
Lab Sample ID: J61121-55
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0038, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1014



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 68
Lab Sample ID: J61121-56
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0012, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1017

Analytical Testing Parameters

Client Sample ID: 50
Lab Sample ID: J61121-57
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1018

Analytical Testing Parameters

Client Sample ID: 67
Lab Sample ID: J61121-58
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1018



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 35B
Lab Sample ID: J61121-59
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1019

Analytical Testing Parameters

Client Sample ID: 66
Lab Sample ID: J61121-60
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1020

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J61121-61
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1020



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 35A
Lab Sample ID: J61121-62
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1021

Analytical Testing Parameters

Client Sample ID: 52
Lab Sample ID: J61121-63
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0011, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1022

Analytical Testing Parameters

Client Sample ID: 9B
Lab Sample ID: J61121-64
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1024



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 37-2
Lab Sample ID: J61121-65
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1024

Analytical Testing Parameters

Client Sample ID: 70
Lab Sample ID: J61121-66
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1026

Analytical Testing Parameters

Client Sample ID: 51
Lab Sample ID: J61121-67
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1027



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 39-2
Lab Sample ID: J61121-68
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1028

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J61121-69
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1028

Analytical Testing Parameters

Client Sample ID: 38-1
Lab Sample ID: J61121-70
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0032, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1029



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 36-2
Lab Sample ID: J61121-71
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1030

Analytical Testing Parameters

Client Sample ID: 39-1
Lab Sample ID: J61121-72
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.026, 0.015, 0.0010, mg/L, G, 10/08/16 0823, 10/11/16 2246

Analytical Testing Parameters

Client Sample ID: 36-1
Lab Sample ID: J61121-73
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0030, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1032





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 53
Lab Sample ID: J61121-74
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1032

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J61121-75
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1033

Analytical Testing Parameters

Client Sample ID: 38-2
Lab Sample ID: J61121-76
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 05:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1035



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J61121

Analytical Testing Parameters

Client Sample ID: 69
Lab Sample ID: J61121-77
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 07:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1036

Analytical Testing Parameters

Client Sample ID: 9A
Lab Sample ID: J61121-78
Sample Type: Grab

Collected By: RF/FH
Collection Date: 09/20/16
Collection Time: 06:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0010, 0.015, 0.0010, mg/L, 10/06/16 0815, 10/13/16 1036

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 23.2°C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611121

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield  
Division Manager  
10/29/2016 16:14

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.*

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

ST. Reg

MNY Workorder #

**Client Information**

Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES  
 Address: 20104 NYS Route 3  
 Watertown, NY 13601  
 Contact: Ray Filley  
 Phone: 315-779-7054  
 Project: Lead Testing  
 Quote ID: PO#: \_\_\_\_\_  
 Rush FAT Bur. Days: 2-5 5-7 7-10 Date Req: \_\_\_\_\_  
 Release to DOH: Yes  
 Email Results: Yes  
 Fax Results: Yes

filley@boces.com / ffilley@boces.com

**Receiving Info (Lab Use Only)**

Ice: YES NO  
 Cooler: YES NO  
 Sample Temp: 23.2  
 Cooler seal: YES NO  
 Pickup: YES NO  
 Dropoff: C W  
 Accepted? YES NO  
 Container Material  
 Container size (in MI)  
 Preservative

Sample Information	Description/Location	Date	Time	Initial	Matrix Type	Analysis Requested		Number of Containers for Analysis Requested	Comments
						Container Material	Container size (in MI)		
1	6	9/20	6:10	RF	P			200.8 Lead	
2	8B		6:12						
3	8A		6:11						
4	4		6:13						
5	3		6:14						
6	5		6:13						
7									
8									



J61121

**Print Name and Company**

Sampled: Ray Filley  
 Received: Ray Filley  
 Received: James Walker  
 Received: \_\_\_\_\_  
 Received: \_\_\_\_\_  
 Received: \_\_\_\_\_

**Signature**

Date/Time: 9/20 9:00  
 9/21/16 14:00  
 9/21/16 14:00

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this practice.

3821 Buck Drive

Cortland NY 13045

Phone:(607)753-3403 Fax:(607)753-3415  
NY #10796, EPA #NY00935

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

ST. Regen

MNY Workorder #

Client Information				Billing/Invoice:			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Onesida BOCES						
Address:	20104 NYS Route 3						
Contact:	Watertown, NY 13601						
Phone:	Ray Filley						
Project:	315-779-7054						
Quote ID:	Lead Testing						
Rush TAT Bus. Days:	2-5 5-7 7-10	PO#:					
Release to DOH: Yes		Date Req:					
Email Results: Yes	rfilley@boces.com						
Fax Results: Yes	rfilley@boces.com / fhawk@boces.com						

  

Sample Information				Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
46B	9/20	6:24	RF				
45B		6:33					
71		7:52					
45A		6:33					
62		6:27					
58		6:15					
46A		6:24					
7		6:11					

  

Receiving Info (Lab Use Only)	Analysis Requested	Day/Time	Signature	Comment
Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		9/20 9:00	Ray Filley	
Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		9/21/13 14:00	Jennifer Walker	
Sample Temp: 23.2		9/21/13 14:00	Billie Walker	
Cooler Seal: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Pickup: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Dropoff: C W				
Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Container Material				
Container Size (in ML)				
Preservative				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

3821 Buck Drive  
Cordland NY 13045  
Phone: (607) 753-3403 Fax: (607) 753-3416  
NY #10796, EPA #NY00935

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

ST. REG

Samples must be returned on ice

MNY Workorder #

Client Information			Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES						Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	20104 NYS Route 3 Watertown, NY 13601						Cooler:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Contact:	Ray Filley						Sample Temp:	23.2
Phone:	315-779-7054						Cooler Seal:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Project:	Lead Testing						Pickup:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Quote ID:							Dropoff:	C W
Rush TAT Bur. Days:	2-5	5-7	7-10				Accepted?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Release to DOH:	Yes						Container Material:	
Email Results:	Yes						Container Size (in MI):	
Fax Results:	Yes						Preservative:	
					Number of Containers for Analysis Requested			Comments/Field Data
Sample Information								
Description/Location	Date	Time	Initial	Matrix Type				
1	57	9/20	6:23 RF	P	200.8 Lead			
2	41	6:27		250				
3	64	6:29		HNO3				
4	65	6:29						
5	63	6:29						
6	61	6:27						
7	3B	6:15						
8	1	6:17						
Print Name and Company					Signature	Date/Time	Comments	
Ray Filley					RF	9/20		
Other: Thomas						9/21/16 1400		
					Jennifer Walker	9/21/16 1400		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

ST. REG

MNY Workorder #

Client Information				Billing/Invoice:			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES						
Address:	20104 NYS Route 3 Watertown, NY 13601						
Contact:	Ray Filley						
Phone:	315-779-7054						
Project:	Lead Testing						
Quote ID:		PO#:					
Rush TAT Bus. Days:	2-5	5-7	7-10	Date Req:			
Release to DOH:	Yes						
Email Results:	Yes			Email:	rfiley@boces.com / fhawk@boce5.com		
Fax Results:	Yes						

  

Sample Information				Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysis Requested	Comments/Field Data
59	9/20	6:25	RF				
11		6:01					
54		6:19					
55		6:19					
60		6:27					
44		6:35					
43		6:35					
42		6:35					

  

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	23.2
Cooler feed:	YES NO
Pickup:	YES NO
Droptoff:	C W
Accepted?	YES NO
Container Material	
Container size (in MI)	
Preservative	

  

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Ray Filley		<i>Ray Filley</i>	9/20/00	
Received: D Thomas		<i>D Thomas</i>	9/20/00 1:45	
Received:		<i>Joseph Waller</i>	9/21/00 1:00	
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

ST. REXA

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Release to DOH: Yes			
Email Results: Yes	rfilley@boces.com		
Fax Results: Yes	fhanck@boces.com		

  

Sample Information				Analysis Requested				Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Container Material	Accepted?	Ice:	YES NO
29	9/20	5:58	RF					2008 Lead	YES NO
19		5:58							YES NO
14		6:00							YES NO
13		5:58							YES NO
16		6:01							YES NO
15		5:58							YES NO
10		5:58							YES NO
17									YES NO

  

Print Name and Company	Signature	Date/Time	Comments
Ray Filley	<i>Ray Filley</i>	9/20 400	
D Thomas	<i>D Thomas</i>	9/21/16 1400	
	<i>Ray Filley</i>	9/21/16 1800	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



# Microbac Laboratories, Inc. CHAIN OF CUSTODY

*St. Reg*

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES					Ice:	YES	NO				
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES	NO				
Contact:	Ray Filley					Sample Temp:	23.2					
Phone:	315-779-7054					Cooler Seal:	YES	NO				
Project:	Lead Testing					Pickup:	YES	NO				
Quote ID:			PO#:			Droptoff:	C	W				
Rush TAT Bur. Days:	2-5	5-7	Date Req:			Accepted?	YES	NO				
Release to DOH: Yes						Container Material						
Email Results: Yes	filley@boces.com					Container Size (in MI)						
Fax Results: Yes	ffhawk@boces.com					Preservative						
Sample Information												
Description/Location	Date	Time	Initial	Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data						
26	9/20	5:49	RF	HNO3								
27		5:49										
24		5:52										
28		5:54										
21		5:54										
22		5:55										
23		5:55										
30		5:49										

  

Print Name and Company	Signature	Date/Time	Comments
Ray Filley	<i>Ray Filley</i>	9/20/00	
P Filley	<i>P Filley</i>	9/21/00	
	<i>Ray Filley</i>	9/21/00	
	<i>Ray Filley</i>	9/21/00	
	<i>Ray Filley</i>	9/21/00	
	<i>Ray Filley</i>	9/21/00	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

ST. Reg

MNY Workorder #

Client Information			Billing/Invoice:		
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES				
Address:	20104 NYS Route 3 Watertown, NY 13601				
Contact:	Ray Filley				
Phone:	315-779-7054				
Project:	Lead Testing				
Quote ID:		PO#:			
Rush TAT Bur. Days:	2-5	5-7	7-10	Date Req:	
Reflects to DOH:	Yes				
Email Results:	Yes				
Fax Results:	Yes				
Email:	rfiley@boces.com				
Fax:	fhawck@boces.com				

  

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)				
Description/Location	Date	Time	Initial	Matrix	Type	Number of Containers for Analysts Requested	Container Material	Accepted?	YES	NO
31	9/20	5:44	RF	P	200.8 Lead					
33		5:43		250						
28B		5:46		HNO3						
32		5:44								
25		5:52								
28A		5:46								
49		5:51								
48		5:50								

  

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Ray Filley		<i>Ray Filley</i>	9/20/00	
D. Francis		<i>D. Francis</i>	9/20/16 14:00	
		<i>George Walker</i>	9/20/16 14:00	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

*St. Regis*

MNY Workorder #

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES					Ice:	YES	NO				
Address:	20104 NYS Route 3					Cooler:	YES	NO				
Contact:	Watertown, NY 13601					Sample Temp:	23.2					
Phone:	Ray Filley					Cooler Seal:	YES	NO				
Project:	315-779-7054					Pickup:	YES	NO				
Quote ID:	Lead Testing					Dropoff:	C	W				
Rush TAT Bus. Days:	< 2-5 5-7 7-10					Accepted?	YES	NO				
Release to DOH: Yes						Container Material:						
Email Results: Yes						Container size (in MI):						
Fax Results: Yes						Preservative:						
						Comments/Field Data						

  

Sample Information				Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Matrix Type		
1 37-1	9/20	5:38	RF	P	200.8 Lead	
2 688		7:48		250		
3 SB		6:03		HNO3		
4 67		7:50				
5 35B		5:34				
6 666		7:50				
7 34		5:43				
8 35A		5:34				

  

Print Name and Company	Signature	Date/Time
Sampled: Ray Filley	<i>[Signature]</i>	9/20 4:00
Received: D Thomas	<i>[Signature]</i>	9/24/00 14:00
Received:	<i>[Signature]</i>	7/11/00 14:00
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

3821 Buck Drive  
Corland NY 13045

Phone: (607) 753-3403 Fax: (607) 753-3415  
NY #10796, EPA #NY00935

# Microbac Laboratories, Inc. Samples must be returned on ice CHAIN OF CUSTODY

St. Louis

MNY Workorder #

<b>Client Information</b>		<b>Billing/Invoice:</b>	
Name: Jefferson-Lewis-Hamilton-Herkimer, Oneida, BOCES			
Address: 20104 NYS Route 3 Watertown, NY 13601			
Contact: Ray Filley			
Phone: 315-779-7054			
Project: Lead Testing			
Quote ID:	PO#:		
Rush TAT Bus. Days: 2-5 5-7 7-10	Date Req:		
Release to DOH: Yes			
Email Results: Yes	rifilley@boces.com / fhauck@boces.com		
Fax Results: Yes			
<b>Sample Information</b>		<b>Analysis Requested</b>	
Description/Location	Date	Time	Initial
1 SZ	9/10	6:05	RF
2 9B		6:04	
3 37-2		5:39	
4 70		7:52	
5 51		6:03	
6 39-2		5:42	
7 12		6:00	
8 38-1		5:39	
<b>Receiving Info (Lab Use Only)</b>		<b>Comments/Field Data</b>	
Ice: YES NO			
Cooler: YES NO			
Sample Temp: 22.2			
Cooler Seal: YES NO			
Pickup: YES NO			
Dropoff: C W			
Accepted: YES NO			
Container Material			
Container size (in ml)			
Preservative			
<b>Number of Containers for Analysis Requested</b>		<b>Comments</b>	
2008 Lead			
P			
250			
HNO3			
<b>Signature and Company</b>		<b>Date/Time</b>	
Sampled: Ray Filley	9/10 9:00		
Received: D. Johnson	9/20/16 1400		
Received:	9/21/16 1400		
Received: Jennifer Walker			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this.

*ST. Regis*

MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer, Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:		PO#:	
Rush FAT Bur. Days:	2-5 5-7 7-10	Date Req:	
Release to DOH: Yes			
Email Results: Yes	rfilley@boces.com		
Fax Results: Yes	ffilley@boces.com		

  

Sample Information		Matrix	
Description/Location	Date	Initial	Type
36-2	9/20	RF	
39-1			
36-1			
53			
46			
38-2			
69			
9A			

  

Sample Information		Matrix	
Date	Time	Initial	Type
9/20	5:38	RF	
	5:41		
	5:37		
	6:05		
	7:47		
	5:34		
	7:08		
	6:04		

  

Receiving Info (Lab Use Only)	
Ice:	YES NO
Cooler:	YES NO
Sample Temp:	23.2
Cooler seal:	YES NO
Pickup:	YES NO
Dropoff:	C W
Accepted?	YES NO

  

Analysis Requested	
Container Material	
Container size (in ml)	
Preservative	
Number of Containers for Analysis Requested	

  

Comments/Field Data	
200.8 Lead	
P	
250	
HNO3	

  

Print Name and Company	Signature	Date/Time	Comments
Ray Filley	<i>[Signature]</i>	9/20/00	
D. Thomas	<i>[Signature]</i>	9/21/00 1400	
	<i>[Signature]</i>	9/21/00 1400	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.